



भारतीय विदेश व्यापार संस्थान
(मानित विश्वविद्यालय)
INDIAN INSTITUTE OF FOREIGN TRADE
(DEEMED TO BE UNIVERSITY)
(AN AUTONOMOUS INSTITUTE OF MINISTRY OF COMMERCE & INDUSTRY)



बी-21, कुतुब इन्स्टीट्यूशनल एरिया नई दिल्ली-110016

B-21, Qutab Institutional Area, New Delhi-110016

Phone : 0091-11-39147200, 39147201, 39147202

Fax : 0091-11-39147214, Website : www.iift.ac.in

Corrigendum to Tender No. IIFT(D)/E&M/1(6)/2024-25

Ref. No. IIFT(D)/E&M/1(6)/2024-25

Dated : 17.12.2024

A pre-bid meeting was held on 13.12.2024 at 3:00 pm in room no-322 for MAINTENANCE & OPERATION OF FIRE DETECTION, ALARM & FIRE-FIGHTING EQUIPMENTS / SERVICES AT IIFT DELHI CAMPUS. The following attended the meeting:-

IIFT

- | | | |
|------------------------|---|--------------------|
| (1) Shri R.K. Gupta | - | Institute Engineer |
| (2) Shri P. Sakthivel | - | SAO(HR) |
| (3) Ms. Nalini Meshram | - | AR (E&M) |
| (4) Ms. Mohini Madaan | - | SO(E&M) |
| (5) Mr. Bishan Pal | - | AO(Fin) |

Representative of Prospective Bidders

- (1) M/s A-One Fire Services (India)
- (2) M/s Shine and Standard
- (3) M/s Alent Enterprises Pvt. Ltd.
- (4) M/s DB Secure Solutions Pvt. Ltd
- (5) M/s National Safety Engineers

The representatives of participating agencies were requested to put forward their doubts or points which needs clarifications. Various request / questions raised by them and the clarifications provided by IIFT are as below:-

S. No.	Pre-bid query	Comments from IIFT
1.	The type of fire pump viz. electrical pump, diesel pump and jockey pump with their HP may be specified.	<ol style="list-style-type: none">1. Following pumps are provided - Electric driven fire pump (1Nos) with 2280 LPM and 75 metre HEAD. The Pump is kirloskar make 60 HP 45KW 1450 RPM2. Diesel Engine Driven Fire Pump (1Nos) 2280 LPM and 75 metre HEAD. The pump is Kirloskar make 83 HP, 1500 RPM3. Electric Driven Jockey Pump (1Nos), 180 LPM 75 Metre HEAD, Kirloskar make, 12.5 HP, 2900 RPM4. Terrace Pump (2Nos) , 900 LPM, 45 metre Head, Kirlokar Make -20 HP, 2900 RPM
2.	The number of smoke detectors may be provided to workout the rates	The fire alarm and detection system at present is functioning in Academic Building and Library

		of Admn. Building. The number of detectors and other accessories provided are as follows: a) Intelligent Analog Addressable Smoke Detector – 151 Nos b) Addressable Manual Call Point – 15 nos. c) Addressable Horn cum Strob – 15 nos d) Two Nos, Intelligent Addressable Main Fire Alarm Panel (Micro Processor based) supporting not less than 240 devices (120 detectors per loop)
3.	In the Price Schedule , Table C , item No. 3 – please clarify whether new CAMT Type Ceiling Mounted HFC Fire Extinguisher are to be provided or only refilling is to be carried out	It is clarified that only refilling is to be carried out. Fire Extinguisher are already provided in the Institute
4	Please clarify what materials are to be provided by the Vendors during maintenance and what are the exclusions.	It is already clarified at Page 8 of the Tender Document. Same is reproduced below:- <i>“All material required for upkeep of the system including Main Fire Pump/Diesel Pump/Jockey Pump/ Pressure gauge etc. shall be arranged by the contractor at his own cost except new pipes, hose reel / pipes, hydrants, Main Fire & Jockey Pump Motor (if required to be replaced). Battery and diesel for diesel engine shall be borne by IIFT.”</i>
5	Please clarify whether Institute shall obtain Workmen Compensation Policy/Insurance policy for those workers whose wages exceeds Rs 21,000/- and ESIC is not applicable to them.	It was Clarified that Vendors has to comply with provisions of Workman Compensation Act at their own cost. Its charges can be suitably included in the service charges to be quoted by the vendor.

Note :

- (i) In view of the above mentioned corrigendum, the date and time for submission of tender is hereby extended to 19.12.2024 upto 15:00 hrs. All other terms and conditions remain unchanged.
- (ii) This corrigendum shall form an integral part of the tender document.

(Handwritten Signature)

Assistant Registrar (E&M)
arem@iift.ac.in

Indian Institute of Foreign Trade, New Delhi